


ActivFlo Installation Location #1




Recommended: Fixture-based Sizing

- 1. For well pump systems, install the ActivFlo after the well tank
- 2. Size the ActivFlo as you would for a municipal system, based on fixture flowrate (see below)
- 1. The ActivFlo ZAF034 or ZAF010 will be suitable based on fixture flowrates

Typical Flow Rates for Residential Fixtures



ActivFlo Operational Flow Rates






ActivFlo Installation Location #2

Pump-based sizing
requires pump flowrate

and well depth to

determine actual
household



Alternative: Pump-based Sizing

If ActivFlo is installed before well tank, sizing is based

on pump flowrate, not domestic fixtures

Sizing scenario 1

- 1. 12 GPM Well Pump (10G10)
- 2. Well depth is 300 feet
- 3. Pump output is 9.7 GPM
- 4. ZAF010H will be suitable based on pump flowrate

Sizing scenario 2

- 1. 12 GPM Well Pump (10G10)
- 2. Well depth is 300 feet
- 3. Pump output is 4.5 GPM
- 4. ZAF034 or ZAF010 will be suitable based on pump flowrate

